

Rack Structural Calculation Report

Project Name: XXX Rack Structural Calculation Report

Client: XXX

Inspection type: Commission

Date: 2025.1.18

Inspected by: Shanghai Wesafe Rack Safety Inspection Technology Co., Ltd

Designed by		Date	
Checked by		Date	
State ment	Without the consent of Shanghai Wesafe Rack Safety Inspection Technology Co., Ltd. and XXX. no one shall let a third party know the content of this report in any form. Shanghai Wesafe Rack Safety Inspection Technology Co., Ltd. solemnly declares: (1) This report is invalid without the official seal of the institution; (2) Part of the reproduction report is invalid without re-affixing the official seal of the institution; (3) The alteration of this report is invalid; (4) This report is only responsible for the content of this test, and our company has the right to interpret the report		
Inspe ction company	Corresponding address: Room 306, Building 2, No.1588 of Huhang Rd., Fengxian District, Shanghai Zip code: 201400 Manager: Yao Kaichen Mobile: E-mail: kaichen@wesafesh.com		
Client	Project address: Greece Corresponding address: Zip code: Manager: Mobile: E-mail:		

目录

1 Basis	5
2 Assumption	6
3 System.....	7
4 Material protperties	8
4.1 Steel	8
4.2 Material safety factor	8
5 Properties of the components and connections	9
5.1 Ordinary position Upright-100*78*2.0	9
5.2 Strengthen position upright-100*78*2.0+100*96*2.5	9
5.3 Back bracing position upright-118*91*3.0+118*91*3.0	10
5.4 Beam 1-100*50*1.5.....	11
5.5 Beam 2-100*50*1.5*2	12
5.6 Bracing C45*30*8*1.3	12
5.7 Back bracing C75*50*15*2.5	13
5.8 Beam end connector	13
5.9 Upright foot joint	13
5.10 Upright frame	14
5.10.1 Looseness of beam-upright	14
5.10.2 Stiffness reduction	14
6 Load and action	15
6.1 Dead load D	15
6.2 Unit loads PL	15
6.2.1 Rate of loads	15
6.3 Placement load	15
6.3.1 Horizontal placement load	15
6.3.2 Vertical placement load HPL.....	15
6.4 Global imperfections ϕ	15
6.4.1 Down-aisle direction.....	16

6.4.2 Cross-aisle direction	16
6.5 Accidental horizontal impact load	16
6.6 Horizontal seismic load Eq	16
7 Load combinations	20
7.1 Global analysis	20
8 Global analysis	21
8.1 Software information	21
8.2 Finite element modal.....	21
8.3 Buckling analysis	22
8.4 Analytical method.....	23
9 Component check.....	24
9.1 Ordinary position Upright-100*78*2.0	24
9.2 Strengthen position upright-100*78*2.0+100*96*2.5	27
9.3 Back bracing position upright-118*91*3.0+118*91*3.0	31
9.4 Bracing C45*30*8*1.3	35
9.5 Beam 1-100*50*1.5.....	38
9.6 Beam 2-100*50*1.5*2	39
9.7 Back bracing C75*50*15*2.5	40
9.8 Upright foot joint	41
9.8.1 Compressive	43
9.8.2 Shear.....	43
9.8.3 Tension.....	43
9.9 Bracing joint.....	44
9.10 Back bracing joint	45
9.10.1 Joint bolt	47

1 Basis

Reference standard	[1]BS EN 15512:2020+A1-2022. Steel static storage systems-Adjustable pallet racking systems-Principles for structural design. [2]BS EN 16681:2016. Steel static storage systems-Adjustable pallet racking systems-Principles for seismic design. [3] EN 1998-1:2004. Eurocode 8: Design of structures for earthquake resistance - Part 1: General rules, seismic actions and rules for buildings.
Results	Through calculation, the rack structural meets the standard requirements.
Suggestion	It's suggested to establish three different inspection hierarchies for storage racks: (1) Instant inspection. Once problems are found in daily use, need to reported to the nominated Person Responsible for Rcking Safety who is responsible for carrying out a preliminary inspection and taking action where necessary. (2) Regular inspection. Person Responsible for Racking Safety should conduct regular inspection and make documented action points for any serious damage. Person Responsible for Racking Safety should conduct regular maintaince, such as FLT operator training, warehouse stuff safety awareness training and bolts tightening and rust removing. (3) Professional inspection. At least once a year professional inspection of the whole racking system, carried out by a qualified testing organization.

2 Assumption

(1) The frequency of discharge and unloading is low, without considering the fatigue effect.

(2) The floor where the racks are located can be regarded as rigid floor, and the floor will not produce deformation that causes additional force on the racks.

(3) Storage management can ensure that the full load rate of the racks does not exceed the specified values in the table below.

(4) The equivalent section characteristics required for upright verification are replaced by the minimum net section characteristics.

WESAFE

3 System

The rack layout and component section drawings are subject to the CAD file provided by the client.



Rack structural layout plan

4 Material properties

4.1 Steel

Steel properties


Modulus of elasticity	E	=	206000N/mm ²
Shear modulus	G	=	79231N/mm ²
Density	ρ	=	7850kg/m ³
Q235	f_y	=	235N/mm ²
	f_u	=	370N/mm ²
Q355	f_y	=	355N/mm ²
	f_u	=	470N/mm ²

4.2 Material safety factor

$\gamma_{M0}=1.1$, $\gamma_{M2}=1.25$ 。

5 Properties of the components and connections

5.1 Ordinary position Upright-100*78*2.0




Upright section

Upright section properties

Name	Value	Instructions
f_y	355.000	Yield strength of steel (N/mm ²)
E	206000.000	Modulus of elasticity (N/mm ²)
G	79231.000	Shear modulus (N/mm ²)
A_{eq}	477.000	Equivalent area (mm ²)
A_{eff}	462.000	Effective area (mm ²)
$I_{y,eq}$	648273.000	The moment of inertia about the Y-axis (axis of symmetry) (mm ⁴)
$I_{z,eq}$	338897.000	The moment of inertia about the Z-axis (mm ⁴)
$I_{t,eq}$	571.000	Free torsion constant (mm ⁴)
$I_{w,eq}$	905667167.000	Warping torsion constant (mm ⁶)
$y_{0,eq}$	68.220	Centroid cut centroid distance (mm)
$W_{y,eff}$	13343.000	Effective section modulus around the Y-axis (mm ³)
$W_{z,eff,min}$	6407.000	Lesser effective section modulus around the Z-axis (mm ³)
$W_{z,eff,max}$	10625.000	Larger effective section modulus around the Z-axis (mm ³)


5.2 Strengthen position upright-100*78*2.0+100*96*2.5



Upright section properties

Name	Value	Instructions
f_y	355.000	Yield strength of steel (N/mm ²)
E	206000.000	Modulus of elasticity (N/mm ²)
G	79231.000	Shear modulus (N/mm ²)
A_{eq}	1299.000	Equivalent area (mm ²)
A_{eff}	1126.635	Effective area (mm ²)
$I_{y,eq}$	1809806.000	The moment of inertia about the Y-axis (axis of symmetry) (mm ⁴)
$I_{z,eq}$	3534267.000	The moment of inertia about the Z-axis (mm ⁴)
$I_{t,eq}$	1505184.000	Free torsion constant (mm ⁴)
$I_{w,eq}$	905667167	Warping torsion constant (mm ⁶)
$y_{0,eq}$	72.680	Centroid cut centroid distance (mm)
$W_{y,eff}$	31193.82	Effective section modulus around the Y-axis (mm ³)
$W_{z,eff,min}$	31713.332	Lesser effective section modulus around the Z-axis (mm ³)
$W_{z,eff,max}$	39431.776	Larger effective section modulus around the Z-axis (mm ³)

5.3 Back bracing position upright-118*91*3.0+118*91*3.0




Upright section

Upright section properties

Name	Value	Instructions
f_y	355.000	Yield strength of steel (N/mm ²)
E	206000.000	Modulus of elasticity (N/mm ²)
G	79231.000	Shear modulus (N/mm ²)
A_{eq}	2020.000	Equivalent area (mm ²)
A_{eff}	1798.629	Effective area (mm ²)
$I_{y,eq}$	10612237.000	The moment of inertia about the Y-axis (axis of symmetry) (mm ⁴)
$I_{z,eq}$	1850595.000	The moment of inertia about the Z-axis (mm ⁴)
$I_{t,eq}$	7833.000	Free torsion constant (mm ⁴)
$I_{w,eq}$	1811334334	Warping torsion constant (mm ⁶)
$y_{0,eq}$	68.220	Centroid cut centroid distance (mm)
$W_{y,eff}$	79028.642	Effective section modulus around the Y-axis (mm ³)
$W_{z,eff,min}$	332644.850	Lesser effective section modulus around the Z-axis (mm ³)
$W_{z,eff,max}$	44202.922	Larger effective section modulus around the Z-axis (mm ³)

5.4 Beam 1-100*50*1.5




Beam section

Beam section properties

Name	Value	Instructions
MRd,y	3687062.000	Strong axial moment bearing capacity (Nmm)
MRd,z	2546524.000	Weak axial moment bearing capacity (Nmm)

5.5 Beam 2-100*50*1.5*2




Beam section

Beam section properties

Name	Value	Instructions
MRd,y	12591327.000	Strong axial moment bearing capacity (Nmm)
MRd,z	8139434.000	Weak axial moment bearing capacity (Nmm)

5.6 Bracing C45*30*8*1.3




Bracing section

Bracing section properties

Name	Value	Instructions
f_y	235.000	Yield strength of steel (N/mm ²)
f_u	370.000	Tensile strength of steel (N/mm ²)
E	206000.000	Modulus of elasticity (N/mm ²)
G	79231.000	Shear modulus (N/mm ²)
A_n	132.000	Minimum net sectional area (mm ²)
A	146.000	Total sectional area (mm ²)
A_{eff}	132.000	Effective area (mm ²)
I_y	48868.000	The moment of inertia about the Y-axis (axis of symmetry) (mm ⁴)
I_z	17789.000	The moment of inertia about the Z-axis (mm ⁴)
I_t	82.000	Free torsion constant (mm ⁴)
I_w	8195996.000	Warping torsion constant (mm ⁶)
y_0	25.560	Centroid cut centroid distance (mm)
$W_{z,eff}$	914.000	Lesser effective section modulus around the Z-axis (mm ³)

5.7 Back bracing C75*50*15*2.5



Back bracing section

Back bracing section properties

Name	Value	Instructions
f_u	350.000	Tensile strength of steel (N/mm ²)
A_n	442.000	Minimum net sectional area (mm ²)

5.8 Beam end connector

Beam end connector properties

Properties	kNm/rad
K_b	150

5.9 Upright foot joint

Upright foot joint properties

Properties	kNm/rad
K _{C-2}	147
K _{C-3}	0

5.10 Upright frame

5.10.1 Looseness of beam-upright

$$\Phi_I = 1.0 \times 10^{-3} \text{ rad.}$$

5.10.2 Stiffness reduction

The stiffness of the upright brace is reduced to 5% in accordance with BS EN 15512 Section 9.2.3.4.

9.2.3.4 Upright frames

For upright frame design, in addition to 9.2.3.1, the shear flexibility of the bracing system including the flexibility of the connections between the uprights and the bracing members shall be considered. This shall be determined by test according to A.2.4. Where the height to width ratio of the frames is less than 10 and the racking is not subjected to lateral crane, wind or seismic loads, this test is not required and the reduction in transverse stiffness may be accounted for by reducing the axial stiffness of the bracing members of the upright frame to 5 % of the unreduced value. This reduction includes also the effect of looseness that therefore need not to be considered as initial out-of-plumb.

6 Load and action

6.1 Dead load D

In the finite element model, the software automatically generates the dead load of the rack member.

6.2 Unit loads PL

The pallet load is placed on the shuttle rail and can be regarded as a uniform load along the rail:

5450mm shuttle rail: $q_1 = 1200 \times 10.0 \times 5 / 2 / 5450 = 5.505 \text{ N/mm}$;

7600mm shuttle rail: $q_2 = 1200 \times 10.0 \times 7 / 2 / 7600 = 5.526 \text{ N/mm}$.

6.2.1 Rate of loads

Down-aisle direction seismic: 80%, cross-aisle direction seismic: 100%;

Others: 100%

6.3 Placement load

6.3.1 Horizontal placement load

Rack height 9050mm,

Down-aisle: $2 Q_{ph} = 0.5 \text{ kN}$, $Q_{ph} = 0.25 \text{ kN}$, Every layer of beams;

Cross-aisle: $Q_{ph} = 0.25 \text{ kN}$, acting on the top beam beam-upright connector.

6.3.2 Vertical placement load HPL

25% of the load of a single pallet, placed in the most unfavorable position (in the middle of a single beam span);

$HPL-V = 1200 \times 10.0 \times 25\% = 3000 \text{ N}$

6.4 Global imperfections ϕ

6.4.1 Down-aisle direction

Ultimate limit state:

$$\Phi_0 = 3/2 \times 1/350 = 0.0043$$

$$\alpha_h = 1$$

$$n_{da} = 52$$

$$\alpha_{da} = (0.5(1 + 1/52))^{0.5} = 0.714$$

$$\Phi_{l,BEC} = 0.001$$

$$\Phi_0 \alpha_h \alpha_{da} = 0.0043 \times 1 \times 0.714 = 0.0031 > 1/500$$

$$\Phi_{ULS} = 0.0031 + 0.001 = 0.0041$$

Serviceability limit state:

$$\Phi_{SLS} = 1/350 + 0.001 = 0.0039$$

6.4.2 Cross-aisle direction

Ultimate limit state:

$$\Phi_0 = 3/2 \times 1/350 = 0.0043$$

$$\alpha_h = 1$$

$$n_{ca} = 10$$

$$\alpha_{ca} = (0.5(1 + 1/10))^{0.5} = 0.742$$

$$\Phi_{l,fr} = 1/1000 = 0.001$$

$$\Phi_0 \alpha_h \alpha_{ca} = 0.0043 \times 1 \times 0.742 = 0.0032$$

$$\Phi_{ULS} = 0.0032 + 0.001 = 0.0042 > 1/500$$

Serviceability limit state:

$$\Phi_{SLS} = 1/350 + 1/1000 = 0.0039$$

6.5 Accidental horizontal impact load

Down-aisle: 1.25kN, acting on the upright 300mm from the ground;

Cross-aisle: 2.50kN, acting on the upright 400mm from the ground.

6.6 Horizontal seismic load Eq

The project is located in Greece and is calculated according to the following seismic information as specified by the client:

Table 3.2: Values of the parameters describing the recommended Type 1 elastic response spectra

Ground type	S	T_B (s)	T_C (s)	T_D (s)
A	1,0	0,15	0,4	2,0
B	1,2	0,15	0,5	2,0
C	1,15	0,20	0,6	2,0
D	1,35	0,20	0,8	2,0
E	1,4	0,15	0,5	2,0

(4)P For the horizontal components of the seismic action the design spectrum, $S_d(T)$, shall be defined by the following expressions:

$$0 \leq T \leq T_B : S_d(T) = a_g \cdot S \cdot \left[\frac{2}{3} + \frac{T}{T_B} \cdot \left(\frac{2,5}{q} - \frac{2}{3} \right) \right] \quad (3.13)$$

41

EN 1998-1:2004 (E)

$$T_B \leq T \leq T_C : S_d(T) = a_g \cdot S \cdot \frac{2,5}{q} \quad (3.14)$$

$$T_C \leq T \leq T_D : S_d(T) \begin{cases} = a_g \cdot S \cdot \frac{2,5}{q} \cdot \left[\frac{T_C}{T} \right] \\ \geq \beta \cdot a_g \end{cases} \quad (3.15)$$

$$T_D \leq T : S_d(T) \begin{cases} = a_g \cdot S \cdot \frac{2,5}{q} \cdot \left[\frac{T_C T_D}{T^2} \right] \\ \geq \beta \cdot a_g \end{cases} \quad (3.16)$$


where

a_g, S, T_C and T_D are as defined in 3.2.2.2;

$S_d(T)$ is the design spectrum;

q is the behaviour factor;

β is the lower bound factor for the horizontal design spectrum.



According to the information provided by the client, it can be seen from Table 1 of BS EN 16681 that the structural importance factor $\gamma_1=0.67$;

Table 1 — Importance factors for racks

Importance Class	Description	Importance factor γ_1	
		30 years design life	50 years design life
I	Warehouses with fully automated storage operations	0,67	0,8
II	Standard warehouse conditions, including picking areas	0,84	1,0
III	Any kind of rack with random public access for private customer	N/A	1,2
IV	Hazardous product storage (Hazardous products storage is subject to the approval of National Authorities) Strategic facilities	N/A	1,4

14

BS EN 16681:2016
EN 16681:2016 (E)

The default value of conventional warehouse racks shall be 30 years for Class I and II, and 50 years for clad rack buildings.

According to the relevant content of Section 7.5 of BS EN 16681, the seismic response spectrum is modified: down-aisle $KD=1.0 \times 0.8=0.8$, transverse $KD=0.9 \times 0.8=0.72$. The finite element model of the structure shows that the natural period $T_{down}=1.023s$ and the $T_{cross}=1.393s$.

7.5.1 General

The seismic design of racks shall be performed using the following modified design spectrum:

$$S_{d,mod} = K_D \times S_d(T) \quad (7)$$

where

$S_d(T)$ is the reference design spectrum defined in EN 1998-1

E_{D1} and E_{D3} are the design spectrum modification factors, with $E_{D1} \cdot E_{D3} \geq 0,4$

$$K_D = 1 - P_{E,prod} / P_E \times (1 - E_{D1} \times E_{D3}) \quad (8)$$

where:

P_E is the total weight of the rack in the seismic design situation (including dead weight, permanent weight, live load in the seismic situation and the stored product weight);

$P_{E,prod}$ is the total product weight stored on the rack, in the seismic design situation.

$K_D = E_{D1} \times E_{D3}$ can be assumed when $P_{E,prod}$ is greater or equal to 90 % of P_E .

a) E_{D1} is affected by the following parameters:

- 1) intensity of the seismic action;
- 2) number of load levels, total mass and flexibility of the racking structure, expressed by the period of vibration (dominant period in the direction considered);
- 3) maximum horizontal force that can be transmitted by the unit load to the beams, expressed in terms of the unit load-beam friction coefficient;

$$E_{D1} = \max[0, 4; \mu_S / S_e(T_1) + 0, 2] \leq 1, 0 \quad (9)$$

where

- μ_S is the reference value of the unit load-beam friction coefficient given in 7.5.3
- T_1 is the fundamental period of vibration of the racking structure in the considered direction (the period with highest modal participating mass in the considered direction)
- $S_e(T_1)$ is the ordinate of the elastic spectrum defined in EN 1998-1 (normalized by g) with the viscous damping as defined in 6.2.

When unit loads are restrained on the beams by means of any special system (for example materials increasing the friction between pallet and beam), $E_{D1} = 1, 0$.

b) E_{D3} is a reduction coefficient of the seismic action.

The value of E_{D3} is 0,80

The elastic spectrum defined in EN 1998-1 is as follows.

3.2.2.2 Horizontal elastic response spectrum

(1)P For the horizontal components of the seismic action, the elastic response spectrum $S_e(T)$ is defined by the following expressions (see Figure. 3.1):

$$0 \leq T \leq T_B : S_e(T) = a_g \cdot S \cdot \left[1 + \frac{T}{T_B} \cdot (\eta \cdot 2,5 - 1) \right] \quad (3.2)$$

$$T_B \leq T \leq T_C : S_e(T) = a_g \cdot S \cdot \eta \cdot 2,5 \quad (3.3)$$

$$T_C \leq T \leq T_D : S_e(T) = a_g \cdot S \cdot \eta \cdot 2,5 \left[\frac{T_C}{T} \right] \quad (3.4)$$

$$T_D \leq T \leq 4s : S_e(T) = a_g \cdot S \cdot \eta \cdot 2,5 \left[\frac{T_C T_D}{T^2} \right] \quad (3.5)$$

7 Load combinations

7.1 Global analysis

Load combinations

Group-1: ULS with only PL	
G1-LC01	$1.3D+1.40PL+ImpX$
G1-LC02	$1.3D+1.40PL+ImpY$
Group-2: ULS with PL+PHL	
G2-LC01	$1.3D+1.26PL+1.26PHL-X+ImpX$
G2-LC02	$1.3D+1.26PL+1.26PHL-X+ImpY$
Group-3: ULS with PL+A	
G3-LC01	$1.0D+1.0PL+1.0AX+ImpX$
G3-LC02	$1.0D+1.0PL+1.0AY+ImpY$
Group-4: ULS with PL+EQ	
G4-LC01	$1.0D+0.8PL+1.0EqX+0.3EqY$
G4-LC02	$1.0D+0.8PL+1.0EqY+0.3EqX$
Group-5: SLS with only PL	
G5-LC01	$1.0D+1.0PL+ImpX$
G5-LC02	$1.0D+1.0PL+ImpY$
Group-6: SLS with PL+PHL	
G6-LC01	$1.0D+0.9PL+0.9PHL-X+ImpX$
G6-LC02	$1.0D+0.9PL+0.9PHL-X+ImpY$

Where,

ULS: Ultimate limit state

SLS: Serviceability limit state

ImpX: Global imperfection in down-aisle direction

ImpY: Global imperfection in cross-aisle direction

HPL-X: Horizontal placement in down-aisle direction

HPL-Y: Horizontal placement in cross-aisle direction

Eq: Horizontal seismic actions

A: Accidental horizontal impact load

8 Global analysis

8.1 Software information

The structural computing software used in this calculation is SAP2000. SAP2000 is a rich and powerful finite element computing software, such as modeling function, editing function, analysis function, load function, custom function and design function.


8.2 Finite element modal

The finite element model is established according to the drawings provided by the entruster, as shown in the figure below. The end release of the component, stiffness of the node and other characteristics should be considered in the model, which will not be discussed here. The storage unit load needs to consider the unfavorable load arrangement, as shown in the following figure. Other load models are not discussed here.


The horizontal distance between upright and beam center:

$$e = d_{\text{beam}}/2 - y_{s,\text{upright}} = 50/2 - 29.34 = -4.34\text{mm} < 0.25d_u = 0.25 \times 100 = 25\text{mm};$$

The eccentricity can be negligible.



Full finite element modal-full load




Structural finite element model - top level only

8.3 Buckling analysis

Firstly, the elastic buckling analysis was carried out, and the load condition was considered as 1.3D+1.4 PL(Full).

The first global I buckling mode is shown in the figure below, and the corresponding buckling coefficient is $2.0 < 7.355 < 10.0$, which meets the requirements of EN standard.

Besides, because $3.333 < 7.355 < 10.0$, the second-order effects should be indirectly considered in the global analysis.



Global buckling mode

8.4 Analytical method

- Linear elasticity of material
- Consider the global imperfection
- The seismic is calculated by mode decomposition response spectrum method
- Preset P- Δ effect

9 Component check

9.1 Ordinary position Upright-100*78*2.0

All 100*78*2.0 uprights were checked, and the internal force of the most unfavorable upright section was shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table

ID	4347	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
fy	355.000	N/mm ²
γ M0	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
Aeq	477.000	mm ²
Aeff	462.000	mm ²
Iy,eq	648273.000	mm ⁴

Iz,eq	338897.000	mm ⁴
It,eq	571.000	mm ⁴
Iw,eq	905667167.000	mm ⁶
y0,eq	68.220	mm
Wy,eff	13343.000	mm ³
Wz,eff,min	6407.000	mm ³
Wz,eff,max	10625.000	mm ³
Ly	2475.000	mm
Lz	1200.000	mm
Lt	1200.000	mm
Ky	1.000	
Kz	1.000	
Kt	0.700	
α_y	0.340	
α_z	0.340	
α_{LT}	0.340	
Nc,Rd	149100.000	N
My,Rd	4306150.000	Nmm
Mz,Rd,min	2067713.636	Nmm
Mz,Rd,max	3428977.273	Nmm
iy	36.865	mm
iz	26.655	mm
i0	81.997	mm
λ_y	67.136	
Ncr,y	215166.420	N
$\lambda_{y,rel}$	0.873	
Φ_y	0.996	
χ_y	0.678	
Nby,Rd	101157.357	N
λ_z	45.020	
Ncr,z	478489.264	N
$\lambda_{z,rel}$	0.585	
Φ_z	0.737	
χ_z	0.844	
Nbz,Rd	125883.325	N
β	0.308	
Ncr,T	394862.279	N
Ncr,TF	150739.078	N
$\lambda_{TF,rel}$	1.043	
Φ_{TF}	1.187	
χ_{TF}	0.570	
NFT,Rd	84977.876	N
$\lambda_{T,rel}$	0.644	
Φ_T	0.783	
χ_T	0.814	
NT,Rd	121383.706	N
N	53207.862	N
My	4904.431	Nmm
Mz	85653.529	Nmm


$\alpha \beta \delta y$	0.850	
$\alpha \beta \delta z$	0.850	
$(N_{Ed}/\times N_{c,Rd}) \alpha y$	0.672	
$(M_{y,Ed}/\times L T M_{y,Rd}) \beta y$	0.003	
$(M_{z,Ed}/M_{z,Rd}) \delta y$	0.067	
DCR1	0.742	
$(N_{Ed}/\times z N_{c,Rd}) \alpha z$	0.481	
$(M_{y,Ed}/\times L T M_{y,Rd}) \beta z$	0.003	
$(M_{z,Ed}/M_{z,Rd}) \delta z$	0.067	
DCR2	0.551	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
f_y	355.000	N/mm ²
γM_0	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
A_{eq}	477.000	mm ²
A_{eff}	462.000	mm ²
$I_{y,eq}$	648273.000	mm ⁴
$I_{z,eq}$	338897.000	mm ⁴
$I_{t,eq}$	571.000	mm ⁴
$I_{w,eq}$	905667167.000	mm ⁶
$y_{0,eq}$	68.220	mm
$W_{y,eff}$	13343.000	mm ³
$W_{z,eff,min}$	6407.000	mm ³
$W_{z,eff,max}$	10625.000	mm ³
L_y	2475.000	mm
L_z	1200.000	mm
L_t	1200.000	mm
K_y	1.000	
K_z	1.000	
K_t	0.700	
αy	0.340	
αz	0.340	
$\alpha L T$	0.340	
$N_{c,Rd}$	149100.000	N
$M_{y,Rd}$	4306150.000	Nmm
$M_{z,Rd,min}$	2067713.636	Nmm
$M_{z,Rd,max}$	3428977.273	Nmm
i_y	36.865	mm
i_z	26.655	mm
i_0	81.997	mm
λy	67.136	
$N_{cr,y}$	215166.420	N
$\lambda_{y,rel}$	0.873	
Φy	0.996	
χy	0.678	
$N_{b,y,Rd}$	101157.357	N
λz	45.020	
$N_{cr,z}$	478489.264	N

$\lambda_{z,rel}$	0.585	
Φ_z	0.737	
$\times_z$	0.844	
Nbz,Rd	125883.325	N
β	0.308	
Ncr,T	394862.279	N
Ncr,TF	150739.078	N
$\lambda_{TF,rel}$	1.043	
Φ_{TF}	1.187	
$\times_{TF}$	0.570	
NFT,Rd	84977.876	N
$\lambda_{T,rel}$	0.644	
Φ_T	0.783	
$\times_T$	0.814	
NT,Rd	121383.706	N
N	59214.266	N
My	197978.321	Nmm
Mz	316353.008	Nmm
$\alpha \beta \delta_y$	0.850	
$\alpha \beta \delta_z$	0.850	
$(N_{Ed}/\times N_{c,Rd}) \alpha_y$	0.736	
$(M_{y,Ed}/\times LTM_{y,Rd}) \beta_y$	0.073	
$(M_{z,Ed}/M_{z,Rd}) \delta_y$	0.203	
DCR1	1.011	
$(N_{Ed}/\times zN_{c,Rd}) \alpha_z$	0.527	
$(M_{y,Ed}/\times LTM_{y,Rd}) \beta_z$	0.073	
$(M_{z,Ed}/M_{z,Rd}) \delta_z$	0.203	
DCR2	0.802	

By calculation, the maximum stress ratio of the upright under the most unfavorable static condition $DCR=0.742 < 1.0$; Under the most unfavorable seismic conditions, the maximum stress ratio $DCR=1.011 > 1.0$, but the overlimit ratio is small. It can be considered to meet the bearing requirements.

9.2 Strengthen position upright-100*78*2.0+100*96*2.5

All 100*78*2.0+100*96*2.5 uprights were checked, and the internal force of the most unfavorable upright section was shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table

ID	4856	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
fy	355.000	N/mm ²
γ M0	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
Aeq	1299.000	mm ²
Aeff	1126.635	mm ²
Iy,eq	1809806.000	mm ⁴
Iz,eq	3534267.000	mm ⁴
It,eq	1505184.000	mm ⁴
Iw,eq	905667167.000	mm ⁶
y0,eq	72.680	mm
Wy,eff	31193.82	mm ³
Wz,eff,min	31713.332	mm ³
Wz,eff,max	39431.776	mm ³
Ly	144.000	mm
Lz	1200.000	mm
Lt	1200.000	mm

Ky	1.000	
Kz	1.000	
Kt	0.700	
α_y	0.340	
α_z	0.340	
α_{LT}	0.340	
Nc,Rd	363596	N
My,Rd	10067000	Nmm
Mz,Rd,min	10235000	Nmm
Mz,Rd,max	12726000	Nmm
iy	37.326	mm
iz	52.161	mm
i0	96.935	mm
λ_y	3.858	
Ncr,y	177449183.455	N
$\lambda_{y,rel}$	0.047	
Φ_y	0.475	
χ_y	1.000	
Nby,Rd	363600	N
λ_z	23.006	
Ncr,z	4990037.729	N
$\lambda_{z,rel}$	0.283	
Φ_z	0.554	
χ_z	0.970	
Nbz,Rd	352790	N
β	0.438	
Ncr,T	12969530	N
Ncr,TF	12442110	N
$\lambda_{TF,rel}$	0.179	
Φ_{TF}	0.513	
χ_{TF}	1.000	
NFT,Rd	363600	N
$\lambda_{T,rel}$	0.176	
Φ_T	0.511	
χ_T	1.000	
NT,Rd	363600	N
N	57614.776	N
My	3898.610	Nmm
Mz	250468.052	Nmm
$\alpha \beta \delta_y$	1.000	
$\alpha \beta \delta_z$	0.970	
$(N_{Ed}/\chi N_{c,Rd}) \alpha_y$	0.158	
$(M_{y,Ed}/\chi LTM_{y,Rd}) \beta_y$	0.000	
$(M_{z,Ed}/M_{z,Rd}) \delta_y$	0.024	
DCR1	0.183	
$(N_{Ed}/\chi z N_{c,Rd}) \alpha_z$	0.172	
$(M_{y,Ed}/\chi LTM_{y,Rd}) \beta_z$	0.000	
$(M_{z,Ed}/M_{z,Rd}) \delta_z$	0.027	


DCR2	0.200	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
f_y	355.000	N/mm ²
γ_{M0}	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
Aeq	1299.000	mm ²
Aeff	1126.635	mm ²
Iy,eq	1809806.000	mm ⁴
Iz,eq	3534267.000	mm ⁴
It,eq	1505184.000	mm ⁴
Iw,eq	905667167.000	mm ⁶
y0,eq	72.680	mm
Wy,eff	31193.82	mm ³
Wz,eff,min	31713.332	mm ³
Wz,eff,max	39431.776	mm ³
Ly	144.000	mm
Lz	1200.000	mm
Lt	1200.000	mm
Ky	1.000	
Kz	1.000	
Kt	0.700	
α_y	0.340	
α_z	0.340	
α_{LT}	0.340	
Nc,Rd	363596	N
My,Rd	10067000	Nmm
Mz,Rd,min	10235000	Nmm
Mz,Rd,max	12726000	Nmm
iy	37.326	mm
iz	52.161	mm
i0	96.935	mm
λ_y	3.858	
Ncr,y	177449183.455	N
$\lambda_{y,rel}$	0.047	
Φ_y	0.475	
χ_y	1.000	
Nby,Rd	363600	N
λ_z	23.006	
Ncr,z	4990037.729	N
$\lambda_{z,rel}$	0.283	
Φ_z	0.554	
χ_z	0.970	
Nbz,Rd	352790	N
β	0.438	
Ncr,T	12969530	N
Ncr,TF	12442110	N
$\lambda_{TF,rel}$	0.179	
Φ_{TF}	0.513	


$\times TF$	1.000	
NFT,Rd	363600	N
λT_{rel}	0.176	
ΦT	0.511	
$\times T$	1.000	
NT,Rd	363600	N
N	80921.787	N
My	185132.685	Nmm
Mz	2124414.978	Nmm
$\alpha \beta \delta y$	1.000	
$\alpha \beta \delta z$	0.970	
$(N_{Ed}/\times N_{c,Rd}) \alpha y$	0.223	
$(M_{y,Ed}/\times LTM_{y,Rd}) \beta y$	0.018	
$(M_{z,Ed}/M_{z,Rd}) \delta y$	0.208	
DCR1	0.449	
$(N_{Ed}/\times zN_{c,Rd}) \alpha z$	0.240	
$(M_{y,Ed}/\times LTM_{y,Rd}) \beta z$	0.021	
$(M_{z,Ed}/M_{z,Rd}) \delta z$	0.218	
DCR2	0.478	

By calculation, the maximum stress ratio of the upright under the most unfavorable static condition $DCR=0.200 < 1.0$; Under the most unfavorable seismic conditions, the maximum stress ratio $DCR=0.478 < 1.0$, meet the bearing requirements.

9.3 Back bracing position upright-118*91*3.0+118*91*3.0

All 118*91*3.0+118*91*3.0 uprights were checked, and the internal force of the most unfavorable upright section was shown in the figure below. The detailed calculation process is shown in the table below.





Internal diagram of member

Component check table

ID	195	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
f_y	355.000	N/mm ²
γ_{M0}	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
Aeq	2020.000	mm ²
Aeff	1798.629	mm ²
I _{y,eq}	10612237.000	mm ⁴
I _{z,eq}	1850595.000	mm ⁴
I _{t,eq}	7833.000	mm ⁴
I _{w,eq}	1.81E+09	mm ⁶
y _{0,eq}	68.220	mm
W _{y,eff}	79028.642	mm ³
W _{z,eff,min}	332644.85	mm ³
W _{z,eff,max}	44202.922	mm ³
L _y	2475.000	mm
L _z	1200.000	mm
L _t	1200.000	mm
K _y	1.000	
K _z	1.000	
K _t	0.700	
α_y	0.340	
α_z	0.340	
α_{LT}	0.340	
N _{c,Rd}	580467	N
M _{y,Rd}	25505000	Nmm
M _{z,Rd,min}	107354000	Nmm
M _{z,Rd,max}	14265000	Nmm
i _y	72.482	mm
i _z	30.268	mm
i ₀	104.037	mm
λ_y	34.147	
N _{cr,y}	3522276.941	N

$\lambda_{y,rel}$	0.426	
Φ_y	0.629	
χ_y	0.916	
$N_{by,Rd}$	531540	N
λ_z	39.646	
$N_{cr,z}$	2612858.302	N
$\lambda_{z,rel}$	0.494	
Φ_z	0.672	
χ_z	0.887	
$N_{bz,Rd}$	514710	N
β	0.570	
$N_{cr,T}$	539540	N
$N_{cr,TF}$	503440	N
$\lambda_{TF,rel}$	1.126	
Φ_{TF}	1.292	
χ_{TF}	0.520	
$N_{FT,Rd}$	301700	N
$\lambda_{T,rel}$	1.088	
Φ_T	1.243	
χ_T	0.543	
$N_{T,Rd}$	314910	N
N	23021.427	N
M_y	647201.634	Nmm
M_z	75135.945	Nmm
$\alpha \beta \delta_y$	0.850	
$\alpha \beta \delta_z$	0.887	
$(N_{Ed}/\chi_{Nc,Rd}) \alpha_y$	0.112	
$(M_{y,Ed}/\chi_{LTMy,Rd}) \beta_y$	0.044	
$(M_{z,Ed}/M_{z,Rd}) \delta_y$	0.002	
DCR1	0.158	
$(N_{Ed}/\chi_{zNc,Rd}) \alpha_z$	0.064	
$(M_{y,Ed}/\chi_{LTMy,Rd}) \beta_z$	0.038	
$(M_{z,Ed}/M_{z,Rd}) \delta_z$	0.002	
DCR2	0.104	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
f_y	355.000	N/mm ²
γ_{M0}	1.100	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
A_{eq}	2020.000	mm ²
A_{eff}	1798.629	mm ²
$I_{y,eq}$	10612237.000	mm ⁴
$I_{z,eq}$	1850595.000	mm ⁴
$I_{t,eq}$	7833.000	mm ⁴
$I_{w,eq}$	1.81E+09	mm ⁶
$y_{0,eq}$	68.220	mm
$W_{y,eff}$	79028.642	mm ³
$W_{z,eff,min}$	332644.85	mm ³


Wz,eff,max	44202.922	mm ³
Ly	2475.000	mm
Lz	1200.000	mm
Lt	1200.000	mm
Ky	1.000	
Kz	1.000	
Kt	0.700	
α_y	0.340	
α_z	0.340	
α_{LT}	0.340	
Nc,Rd	580467	N
My,Rd	25505000	Nmm
Mz,Rd,min	107354000	Nmm
Mz,Rd,max	14265000	Nmm
iy	72.482	mm
iz	30.268	mm
i0	104.037	mm
λ_y	34.147	
Ncr,y	3522276.941	N
$\lambda_{y,rel}$	0.426	
Φ_y	0.629	
χ_y	0.916	
Nby,Rd	531540	N
λ_z	39.646	
Ncr,z	2612858.302	N
$\lambda_{z,rel}$	0.494	
Φ_z	0.672	
χ_z	0.887	
Nbz,Rd	514710	N
β	0.570	
Ncr,T	539540	N
Ncr,TF	503440	N
$\lambda_{TF,rel}$	1.126	
Φ_{TF}	1.292	
χ_{TF}	0.520	
NFT,Rd	301700	N
$\lambda_{T,rel}$	1.088	
Φ_T	1.243	
χ_T	0.543	
NT,Rd	314910	N
N	106508.091	N
My	6583002.277	Nmm
Mz	969120.713	Nmm
$\alpha \beta \delta_y$	0.850	
$\alpha \beta \delta_z$	0.887	
$(N_{Ed}/\times N_{c,Rd}) \alpha_y$	0.413	
$(M_{y,Ed}/\times LTM_{y,Rd}) \beta_y$	0.316	
$(M_{z,Ed}/M_{z,Rd}) \delta_y$	0.018	
DCR1	0.747	

$(N_{Ed}/\sum z N_{c,Rd}) \alpha z$	0.247	
$(M_{y,Ed}/\sum L T M_{y,Rd}) \beta z$	0.301	
$(M_{z,Ed}/M_{z,Rd}) \delta z$	0.015	
DCR2	0.564	

By calculation, the maximum stress ratio of the upright under the most unfavorable static condition $DCR=0.158 < 1.0$; Under the most unfavorable seismic conditions, the maximum stress ratio $DCR=0.747 < 1.0$, meet the bearing requirements.

9.4 Bracing C45*30*8*1.3

All CC45*30*8*1.3 bracings were checked, and the internal force of the most unfavorable bracing section was shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table

ID	497	
Laod combinations	1.3D+1.4L+1.4ULS-Y-1	
Name	Value	Unit
N _{Ed}	1314.440	N
f _y	235.000	N/mm ²
f _u	350.000	N/mm ²
γ M ₀	1.100	
γ M ₂	1.250	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
A _n	132.000	mm ²
A	146.000	mm ²
A _{eff}	132.000	mm ²

ly	48868.000	Mm ⁴
lz	17789.000	mm ⁴
lt	82.000	mm ⁴
lw	8195996.000	mm ⁶
y0	25.560	mm
Wz,eff	914.000	mm ³
Ly	1297.112	mm
Lz	1297.112	mm
Lt	1297.112	mm
Ky	1.000	
Kz	1.000	
Kt	1.000	
α y	0.490	
α z	0.490	
α LT	0.490	
Nc,Rd	28200.000	N
Mz,Rd	195263.636	
iy	18.295	mm
iz	11.038	mm
i0	33.315	mm
λ y	70.899	
Ncr,y	59052.251	N
λ y,rel	0.725	
Φ y	0.891	
x y	0.709	
Nby,Rd	20002.210	N
λ z	117.511	
Ncr,z	21496.286	N
λ z,rel	1.201	
Φ z	1.467	
x z	0.433	
Nbz,Rd	12215.276	N
β	0.411	
Ncr,T	14777.437	N
Ncr,TF	12721.335	N
λ TF,rel	1.562	
Φ TF	2.053	
x TF	0.295	
NFT,Rd	8330.187	N
λ T,rel	1.449	
Φ T	1.856	
x T	0.332	
NT,Rd	9353.859	N
ey	0.000	mm
MRd.z.eff	270250.000	Nmm
η	1.065	
MEd.Z	0.000	Nmm
α y	0.850	
α z	0.850	
DCR1	0.420	


DCR2	0.303	
DCR3	0.081	
Laod combinations	1.0D+0.8L+1.0QY+0.3QX-1	
Name	Value	Unit
NEd	4007.211	N
fy	235.000	N/mm ²
fu	350.000	N/mm ²
γ M0	1.100	
γ M2	1.250	
E	206000.000	N/mm ²
G	79231.000	N/mm ²
An	132.000	mm ²
A	146.000	mm ²
Aeff	132.000	mm ²
Iy	48868.000	Mm ⁴
Iz	17789.000	mm ⁴
It	82.000	mm ⁴
Iw	8195996.000	mm ⁶
y0	25.560	mm
Wz,eff	914.000	mm ³
Ly	1297.112	mm
Lz	1297.112	mm
Lt	1297.112	mm
Ky	1.000	
Kz	1.000	
Kt	1.000	
α y	0.490	
α z	0.490	
α LT	0.490	
Nc,Rd	28200.000	N
Mz,Rd	195263.636	
iy	18.295	mm
iz	11.038	mm
i0	33.315	mm
λ y	70.899	
Ncr,y	59052.251	N
λ y,rel	0.725	
Φ y	0.891	
χ y	0.709	
Nby,Rd	20002.210	N
λ z	117.511	
Ncr,z	21496.286	N
λ z,rel	1.201	
Φ z	1.467	
χ z	0.433	
Nbz,Rd	12215.276	N
β	0.411	
Ncr,T	14777.437	N
Ncr,TF	12721.335	N
λ TF,rel	1.562	

Φ TF	2.053	
$\times$ TF	0.295	
NFT,Rd	8330.187	N
λ T _{rel}	1.449	
Φ T	1.856	
$\times$ T	0.332	
NT,Rd	9353.859	N
e _y	0.000	mm
MRd.z.eff	270250.000	Nmm
η	1.229	
MEd.Z	0.000	Nmm
α y	0.850	
α z	0.850	
DCR1	0.537	
DCR2	0.388	
DCR3	0.108	

It is calculated that the maximum stress ratio $DCR=0.420 < 1.0$ under the most unfavorable static condition. The maximum stress ratio $DCR=0.537 < 1.0$ under the most unfavorable seismic conditions; Meet the load bearing requirements.

9.5 Beam 1-100*50*1.5

All 100*50*1.5 beams were checked, and the internal forces of the most unfavorable beams were shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table


ID	2815	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
M3	1764475	Nmm
L	1550.000	mm
Qph	250	N
Qpv	3000	N
J	1	
Vq	1.400	
Vh	0.900	

n	1	
MEd,z	135625	Nmm
MEd,y+	1627500	Nmm
MRd,y	3687062	Nmm
MRd,z	2546524	Nmm
DCR	0.876	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
M3	1206979	Nmm
L	1550	mm
Qph	250	N
Qpv	3000	N
J	1	
Vq	1.4	
Vh	0.9	
n	1	
MEd,z	135625	Nmm
MEd,y+	1627500	Nmm
MRd,y	3687062	Nmm
MRd,z	2546524	Nmm
DCR	0.740	

By calculation, the maximum stress ratio DCR of 100*50*1.5 beam under the most unfavorable static condition is $0.876 < 1.0$; The maximum stress ratio $DCR = 0.740 < 1.0$ under the most unfavorable seismic conditions; Meet bearing requirements.

9.6 Beam 2-100*50*1.5*2

All 100*50*1.5*2 beams were checked, and the internal forces of the most unfavorable beams were shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table


ID	2267	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
M3	1766146	Nmm
L	1550.000	mm

Qph	250	N
J	1	N
Vq	1.400	
Vh	0.900	
n	1	
MEd,z	135625	
MEd,y+	1627500	Nmm
MRd,y	12591327	Nmm
MRd,z	8139434	Nmm
DCR	0.258	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
M3	1218416	Nmm
L	1550	mm
Qph	250	N
Qpv	3000	N
J	1	
Vq	1.4	
Vh	0.9	
n	1	
MEd,z	135625	Nmm
MEd,y+	1627500	Nmm
MRd,y	12591327	Nmm
MRd,z	8139434	Nmm
DCR	0.218	

By calculation, the maximum stress ratio DCR of 100*50*1.5*2 beam under the most unfavorable static condition is $0.258 < 1.0$; The maximum stress ratio $DCR = 0.218 < 1.0$ under the most unfavorable seismic conditions; Meet bearing requirements.

9.7 Back bracing C75*50*15*2.5

All the back bracings were checked, and the internal forces of the most unfavorable back bracings were shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

According to the finite element model, the maximum axial tension of the back bracings is 53.716kN. Because the back bracings in the structure was cross-arranged, half of the tie rod will be compressed out of the work under the lateral load in actual use, so the axial tension of a single back bracings should be amplified by 1 times, and the maximum axial tension should be $53.716 \times 2 = 107.432 \text{ kN}$.

Component check table


ID	3349	
Laod combinations	1.3D+1.4L+1.4ULS-X-1	
Name	Value	Unit
fu	470	N/mm ²
Nmax	2768	N
An	442	mm ²
DCR	0.02	
Laod combinations	1.0D+0.8L+1.0QX+0.3QY-1	
Name	Value	Unit
fu	470	N/mm ²
Nmax	107432	N
An	442	mm ²
DCR	0.650	

It is calculated that the maximum stress ratio $\text{DCR} = 0.020 < 1.0$ under the most unfavorable static condition. The maximum stress ratio $\text{DCR} = 0.650 < 1.0$ under the most unfavorable seismic conditions; Meet bearing requirements

9.8 Upright foot joint


Under the overturning condition where only the top beam is loaded and all lower

beam are unloaded, the axial tension/axial pressure on the column is shown in the figure below, where red is the axial pressure and blue is the axial tension:



Axial diagram of upright under overturning condition

According to the finite element model, the maximum pulling force appears at the entrance of the first longitudinal row under longitudinal seismic conditions, with the maximum axial tension/pressure=55.889KN and the maximum shear force =6.699KN; The maximum axial pressure/tension of the remaining positions of the two rows of reinforced columns =21.356KN and the maximum shear force =3.216KN; The maximum axial tension/pressure at the position of non-reinforced column=11.097KN, the maximum shear =0.910KN.



The size of the adjustable screw at the upright foot node is 2*8.8 M20; The anchor bolts at the longitudinal entrance are 2*M20 (5.8 grade) anchors; The remaining position of the strengthening upright is 2*M12 (5.8 grade); The position of the unreinforced upright is 2*M12(5.8 grade).

9.8.1 Compressive

$$2 \times 20 \times 20 \times 3.14 / 4 \times 400 / 1000 = 251.2 \text{ kN} > 55.889 \text{ kN}, \text{ Meet the requirements.}$$

9.8.2 Shear

$$2 \times 20 \times 20 \times 3.14 / 4 \times 320 / 1000 = 200.9 \text{ kN} > 6.699 \text{ kN}, \text{ Meet the requirements.}$$

9.8.3 Tension

The drawing force calculation table provided by the bolt supplier is as follows:

Design resistance										
Anchor size		M8	M10	M12	M16	M20	M24	M27	M30	
Seismic performance C1										
Tension $N_{Rd,seis}$	HAS-U 5.8	[kN]	-	16,0	22,5	27,3	43,3	59,4	-	-
	HAS-U 8.8		-	16,0	22,5	27,3	43,3	59,4	72,6	86,6
	HAS-U A4		-	16,0	22,5	27,3	43,3	59,4	72,6	86,6
	HAS-U HCR		-	16,0	22,5	27,3	43,3	59,4	-	-
Shear $V_{Rd,seis}$	HAS-U 5.8	[kN]	-	8,8	12,0	21,6	34,4	49,6	-	-
	HAS-U 8.8		-	12,8	19,2	35,2	55,2	79,2	103	126
	HAS-U A4		-	10,0	15,0	27,9	38,5	55,8	34,0	41,2
	HAS-U HCR		-	12,8	19,2	35,2	55,2	49,7	-	-
Seismic performance C2										
Tension $N_{Rd,seis}$ HAS-U 8.8		-	-	-	12,1	18,5	-	-	-	
Shear $V_{Rd,seis}$ HAS-U 8.8		-	-	-	32,0	56,8	-	-	-	

Bolt drawing force calculation table

Back bracing plane outermost upright foot

Drawing force check calculation: $2 \times 43.3 = 86.6 \text{ kN} > 55.889 \text{ kN}$, OK;

Adjustable screw weld checking calculation:

$$\beta_f \cdot f_f^w \cdot h_e \cdot l_w = 1.22 \cdot 280 \cdot 0.7 \cdot 6 \cdot (2 \cdot 3.14 \cdot 20 - 2 \cdot 6) = 162.984 \text{ kN} > 55.889 \text{ kN}, \text{ OK};$$

Other position upright foot of the reinforcing upright

Drawing force check calculation: $2 \times 22.5 = 45.0 \text{ kN} > 21.356 \text{ kN}$, OK;

Adjustable screw weld checking calculation:

$$\beta_f \cdot f_f^w \cdot h_e \cdot l_w = 1.22 \cdot 280 \cdot 0.7 \cdot 6 \cdot (2 \cdot 3.14 \cdot 20 - 2 \cdot 6) = 162.984 \text{ kN} > 21.356 \text{ kN}, \text{ OK};$$

Other position upright foots


Drawing force check calculation: $2 \times 22.5 = 45.0 \text{ kN} > 11.097 \text{ kN}$, OK;

Adjustable screw weld checking calculation:

$$\beta_f \cdot f_f^w \cdot h_e \cdot l_w = 1.22 \cdot 280 \cdot 0.7 \cdot 6 \cdot (2 \cdot 3.14 \cdot 20 - 2 \cdot 6) = 162.984 \text{ kN} > 11.097 \text{ kN}, \text{ OK}.$$

9.9 Bracing joint

The internal forces of the most unfavorable transverse bracing joints are shown in the figure below. The detailed calculation process is shown in the table below.



Internal diagram of member

Component check table


Name	Value	Unit
------	-------	------

Sv	4007	N
Sc	4007	N
γ_{M2}	1.25	
nV	1	
e1	16	mm
d	10	mm
t	1.3	mm
f _u	290	N/mm ²
ab	0.533333	
kt	1	
A _s	58	mm ²
f _{ub}	800	N/mm ²
G _d	8.8	
Co	0.6	
DCR1	0.180	
DCR2	0.996	


By calculation, the maximum stress ratio $DCR=0.996 < 1.0$ under the most unfavorable working conditions; Meet the load bearing requirements.

9.10 Back bracing joint


All the joint bolts of the back bracing were checked. The internal forces of the three-layer back bracing under the most unfavorable working conditions are shown in the figure below. The detailed calculation process is shown in the table below.




Layering diagram of back bracing



Layer 1 Internal force diagram



Layer 2 Internal force diagram



Layer 3 Internal force diagram

According to the finite element model, the maximum axial tension of the back bracing is shown in the figure above. Since the back bracing in the structure is cross-arranged, half of the tie rod will be compressed out of work under lateral load in actual use. Therefore, the axial tension of a single back tie rod should be amplified by 1 time, and the maximum axial tension should be as follows: $N1=53.716*2=107.432\text{KN}$ 、 $N2=36.004*2=72.008\text{KN}$ 、 $N3=22.386*2=44.772\text{KN}$.

9.10.1 Joint bolt

Component check table

Name	Layer 1	Layer 2	Layer 3	Unit
Sv	107432	72008	44772	N
Sc	107432	72008	44772	N
γ_{M2}	1.25	1.25	1.25	
nv	2	1	1	
e1	20	20	20	mm
d	16	18	14	mm
t	8	12	8	mm
fu	510	510	510	N/mm ²
ab	0.416667	0.37037	0.47619	
kt	1	1	1	
As	157	192	115	mm ²
fub	800	800	800	N/mm ²
Gd	8.8	8.8	8.8	
Co	0.6	0.6	0.6	
DCR1	0.891	0.977	1.014	
DCR2	0.987426	0.882451	0.823015	

According to the calculation, the maximum stress ratio $DCR=1.014>1.0$ under the most unfavorable working conditions; However, the over-limit ratio is small, which can be considered to meet the bearing requirements

===== Following blank =====



Address:

**Room 306, Building 2, No.1588 Huhang Rd.
Fengxian District, Shanghai**



Website:

<https://www.wesafesh.com/>



Tel:

+86-21-67157048



Mobile:

+86-176-2169-6300



Email:

service@wesafesh.com



**Official
WeChat
Account**



WeChat
Official
Account



WeChat
Channels



Mini
Program



Douyin
Account